

Project:	
Туре:	
Catalog #:	

#### STANDARD



This covered wall unit is designed to provide maximum lumen output in areas such as hallways, bathrooms, kitchens, stairways, and hospitals. An assortment of options in either single or double lamp allows this utility wall and surface mounted unit to satisfy a variety of lighting needs.

### **Construction:**

Housing is designed from heavy gauge die formed steel and finished in either baked white enamel or polvester powder coating. Socket plate is riveted to housing adding to the structural support of the fixture. Lens is extruded white acrylic. End plates are attached by acorn nuts and secure the lens to the fixture.

#### Electrical

All units are furnished with UL Listed Class P thermally protected ballast. Other voltages are available upon request. Fixtures meet requirements for UL Luminaire Standard # 1598. All units comply with National Energy Standard. All units are UL certified damp location M 59006648

### Mounting

Unit is equipped with holes and 7/8" knockouts in housing for surface mounting. Fixture may be mounted individually or with optional joiner bands may be used in a continuous run.

## **Ordering Guide**



**555 Series** 


# **WARRANTY & LISTINGS**




5-year warranty of all electronics and housing.

UL Certified for damp location M 59006648

## DIMENSIONS





Fixture Length						
T12	T12HO	Т8	Length			
F15T12			18"			
F20T12		F17T8	24"			
F30T12		F25T8	36"			
F40T12	F48T12HO	F32T8	48"			

Max weight = 12lbs / 48"

Series	# of Lamps	Lam	ip Size	Ballast Type	Options
555	1.ÁMÁrÁæ{ ] 2. MÁCÁæ{ ]	<u>T8</u> 17 = ØF <sup>™</sup> VÌ 25 =ØG <sup>™</sup> VÌ 32 = ØHĐÀ <b>T12</b> 15= F15T12 20 = F20T12" 30 = F30T12 40= F40T12	<u>T5</u> 14 = F14T5 21 = 21T5 28 = F28T5 <u>T5H0</u> 24 = F24T5 39 = F39T5 54 = F54T5"	120 = 120V MV = Multivolt E-LW = Electronic .77 BF E-O = Electronic 1.18 BF E-DIM = Dimming Unit SET LED N = Wired 1 end hot for LED tubes SET LED N/S = Wired 2 ends hot for LED tubes W/LEDIF = LED ballast driven tubes	EMBMA { ^\*^} & Asapter cA 2BALANCAsapter cA REFS = Silver Reflector OCC-E = External Occupancy Sensor OCC-I = Internal Occupancy sensor BI-LEV = Bi-level dimming system O = grounded outlet TOG = Toggle Switch PULL = Pull chain switch NL = Night Light 3WAY = 3 way system PRIS = Prismatic lens DL = Down light only POLY = Polycarb lens